



सत्यमेव जयते

**Government Of West Bengal**  
**Office Of The Divisional Fire Officer, North 24 Parganas**  
**West Bengal Fire & Emergency Services**  
**Ghoshpara Road, P.O.:- Bengal Enamel, Pin :- 743122**

Memo no.:FSR/0125186231100953

Date: 18-11-2023

**From:**  
**Divisional Fire Officer, North 24 Parganas**  
**West Bengal Fire & Emergency Services**

**To: Arya Bharat Sikshya Pratisthan**  
**LR and RS Dag No- 240, 241, J.L.No-73, Mouza- Jhowdanga, PS- Gaighata, North 24 Parganas, Pin- 743245**

**Sub: Fire Safety Certificate for an Existing construction of G+I storied under group Educational building in the name and style of "ARYA BHARAT SIKSHYA PRATISTHAN" at the premises No. LR and RS Dag No- 240, 241, J.L. No-73, Mouza- Jhowdanga, PS- Gaighata, North 24 Parganas, Pin- 743245.**

This is in reference to your application no. 0125189231100444 dated 27-10-2023 regarding the Fire Safety Certificate for an Existing construction of G+I storied under group Educational building in the name and style of "ARYA BHARAT SIKSHYA PRATISTHAN" at the premises No. LR and RS Dag No- 240, 241, J.L. No-73, Mouza- Jhowdanga, PS- Gaighata, North 24 Parganas, Pin- 743245.

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Fire Safety Certificate for occupancy of the aforesaid building.

**Recommendation:**

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures Need to be incorporated /maintained.

- 1)Driveway must be free from any type of obstruction for Easy movement of Fire appliances, No parking will be allowed on driveway.
- 2)The interior finish decoration of building shall be made with low flame spread materials Confirming I.S Specifications.
- 3)To eliminate risk of fire hazards, good housekeeping both for inside and outside of the building shall be strictly maintained.
- 4)Existing electrical wirings of the whole building shall have to be carefully checked for any wear and tear.
- 5)The notice of fire fighting and evacuation from the building shall be prepared and displayed at all vulnerable places of the building.
- 6)The employees and the security staff shall be conversant with the installed fire fighting equipment of the building and to operate in the event of fire testing.

- 7)Mock drill fire practice and evacuation drill shall be performed periodically with participants of all the occupants of the building.
- 8)First Aid fire fighting system shall be provided as per I.S. specification and shall be checked or renewed once in every year.
- 9)Arrangements shall have to made for regular checking and testing of fire fighting measures in the building keep them perfectly in working condition at all times.
- 10)The fire safety audit to be conducted at regular interval and to be recorded in the fire prevention maintenance register.
- 11)Floor No. with proper exit signage shall be marked at all floors of the building.
- 12)This renewal Fire Safety Certificate is valid for 03 (three) years from the date of issue of this letter.
- 13)Renewal Fire Safety Certificate is to be obtained after every 03 (three) years from the date of issue of this certificate from the Director General, West Bengal Fire & Emergency Services .
- 14)Switch Gear room shall be protected with automatic co2 or DCP extinguisher conforming IS specification.
- 15)A trained Fireman shall be maintained round the clock for safety of the building.
16. 3rd stair which is shown in approved plan drawing must be made within 3months and inform this office,otherwise this Fire Safety Certificate will be treated as cancelled.
- 17)Any deviation/ changes of the building in respect of approved plan drawing without prior permission from this office, the Fire Safety Certificate will be treated as cancelled.

Divisional Fire Officer,North 24 Parganas  
West Bengal Fire & Emergency Services

Memo No.:FSR/012518623110953